

2019 INSPECTION AND MECHANICAL INTEGRITY SUMMIT

JANUARY 28-31
GALVESTON ISLAND
TEXAS | USA

Brought to you by



AMERICAN PETROLEUM INSTITUTE

Case Study: Steam System Risk Mitigation Using RBI

Bio Slide

Robert Sladek

Asset Optimization Consultants (AOC)

Sr. Asset Integrity Consultant

30+ Years in Mechanical Integrity

Field of Expertise: Inspection; RBI;
Mechanical Integrity Management

Industry Involvement: Chairman for API 581
Task Group(Vice-Chair 2012-2018)



What's the Problem?

Fifty-one (51) year old unit

Maintenance activity increasing over time
and unpredictable

Limited inspection history

**Needed a prioritized mitigation plan to
request capital funding for increased
reliability**



2019 INSPECTION AND MECHANICAL
INTEGRITY SUMMIT



Steam System Risk Mitigation using RBI

RBI was used to prioritize mitigation of steam related piping in an aged unit.

- Client's existing semi-quantitative RBI software was used
- Piping was systemized and circuitized
- Production consequence override was used
- Maintenance and Inspection plans were developed for mitigation



2019 INSPECTION AND MECHANICAL INTEGRITY SUMMIT



Scope

440 total piping circuits

5 steam systems

2 condensate systems


1 Boiler Feed Water (BFW) system



2019 INSPECTION AND MECHANICAL
INTEGRITY SUMMIT



Project Planning



DMR Findings

- Boiler water/condensate corrosion
- Erosion/corrosion
- Inferior trim and packing on older valves
- Outdated torqueing procedure
- Majority of internal damage found in small-bore, saturated steam service



2019 INSPECTION AND MECHANICAL INTEGRITY SUMMIT



Default Semi-Quantitative Methodology

- Probability
 - Current state vs. original for base damage factor (DF)
 - Inspections can reduce DF
 - Credits for overdesign: current vs. design
 - Internal, external and cracking DMs
 - Qualitative modeling
- Consequence
 - Designed for PSM processes
 - Calculates for flammability, reactivity and toxicity
 - Allows upgrade based on production loss



2019 INSPECTION AND MECHANICAL INTEGRITY SUMMIT



Production Consequence Methodology

An A-E ranking system was developed.

- A. Unit shutdown
- B. Multiple section shutdown
- C. Reduced rates for unit
- D. Reduced rates for section
- E. No effect on production

Values were assigned by site SMEs



2019 INSPECTION AND MECHANICAL
INTEGRITY SUMMIT



Risk Results

Combined Risk Distribution

		Combined Risk Distribution						
		Totals						
		E	D	C	B	A		
47.0%	207	0	179	22	0	6		
4.8%	21	8	6	4	0	3		
11.1%	49	5	22	15	0	7		
5.2%	23	2	0	12	0	9		
31.8%	140	10	12	21	0	97		
	440	25	219	74	0	122	Totals	
		6%	50%	17%	0%	28%		

Internal Risk Distribution

		Internal Risk Distribution						
		Totals						
		E	D	C	B	A		
1	196	0	170	20	0	6		
2	16	4	7	4	0	1		
3	58	5	29	17	0	7		
4	24	2	1	11	0	10		
5	146	14	12	22	0	98		
	440	25	219	74	0	122	Totals	

External Risk Distribution

		External Risk Distribution						
		Totals						
		E	D	C	B	A		
1	67	0	59	7	0	1		
2	53	4	42	4	0	3		
3	1	0	0	1	0	0		
4	5	0	0	1	0	4		
5	314	21	118	61	0	114		
	440	25	219	74	0	122	Totals	



Maintenance Recommendations

- Repair/replace piping with clamps/leaks.
 - Due dates based on risk except A consequence
- Design and install bypass for A consequence
 - Due dates based on risk
- Update piping/valve specifications
- Update torqueing procedure to reflect PCC1
- Rework all flanges in A and C Consequence piping



2019 INSPECTION AND MECHANICAL INTEGRITY SUMMIT



Inspection Plans

Grouping of inspections was performed per site methodology.

Implementation methodology developed for past due inspections.



2019 INSPECTION AND MECHANICAL INTEGRITY SUMMIT



Project Results

- Provided a prioritized plan to address an aging steam system
- Consistent and documented approach
- Recommendations to improve site specifications and procedures
- Maintenance plans to improve reliability
- Inspection plans to address all known damage mechanisms



2019 INSPECTION AND MECHANICAL INTEGRITY SUMMIT

